

**BANKI
KUU YA
KENYA**



**CENTRAL
BANK OF
KENYA**

**Haile Selassie Avenue
P.O. Box 60000 - 00200 Nairobi Kenya
Telephone: 2861000/2863000,
Email: supplies@centralbank.go.ke**

ADDENDUM NO. 1

TENDER NO. CBK/032/2015-2016: SUPPLY, DELIVERY, INSTALLATION, TESTING AND COMMISSIONING OF 1 NO. 1000 KVA SOUND-PROOFED GENERATOR AT CENTRAL BANK OF KENYA HEADQUARTERS

This Addendum No. 1 forms part of the Tender Document already issued and advertised in both the **Daily Nation and The Standard** and then uploaded to Central Bank of Kenya website (www.centralbank.go.ke) and IFMIS Portal (www.supplier.treasury.go.ke) on Monday 7th March 2016. The Addendum is issued in response to a request for clarifications made by a prospective tenderer as below:

Issue Raised	Response
The tenderer enquired on the following issues; a) Whether the procuring entity can allow the alternative supply of 2 x 500KVA Prime generators adding up to the 1000kva that are readily available in the stock of the manufacturer. During pre-bid visit the tenderer and CBK will evaluate any if there site changes and absorb costs in the bid. Advantage of using 2 x 500kva is energy saving compared to running one unit of 1000kva during low electrical load below 500kva.	a) No. The Bank requires just 1 No. 1000 KVA Generator.

<p>b) Correct wording for Section A item 9 on consent from CBK Branch Manager , Kisumu</p> <p>c) Correct wording for Section B item 4 on consent from CBK Branch Manager , Kisumu</p> <p>d) Section A (1) (o) -Performing 100% full load testing with 100% resistive load on Page 40. Can the manufacturer factory test be representative of the 100% resistive load to minimise need for having the test equipment on your site?</p>	<p>b) Correct wording for Section A item 9 on consent to read: from Acting Director, Department of Procurement and Logistics Services.</p> <p>c) Correct wording for Section B item 4 on consent to read: from Acting Director, Department of Procurement and Logistics Services.</p> <p>d) No. There will be full load testing at the site at installation stage.</p> <p>Please note that all other details of the original tender document remain the same. The tender opening date remains Monday 21st March 2016 at 10.30 a.m. in the DPLS Conference Room, 5th Floor CBK Building.</p>
---	---

AG. DIRECTOR
DEPARTMENT OF PROCUREMENT & LOGISTICS SERVICES

14th March, 2016